

Fact sheet

Fire protection & safety at food stands



1 Fire blanket (Mind. 180 x 120cm)

Every food stall (food preparation) must be equipped with a fire blanket.


2 Fire extinguisher (6 kg Light Water or CO2 extinguisher)

Each stand has **a tested** fire extinguisher. **ALL 3** years or according to manufacturer's instructions.



3 Non flammable base


Each stand must be equipped with a non-flammable support plate, unless the shelf is made of chrome steel or similar materials. Eternit or metal plate, for example.



4 Passageways to buildings

Passageways must be kept accessible at all times and must not be adjusted.

The building distance of 120 cm must be maintained.



5 Torch testing

A **valid test certificate** must be available for the gas burner in order to put the device into operation! Devices with invalid vignette must not be put into operation. Old or damaged connection tubes must be replaced.



6 Electrical installations

Electrical installations must be installed in such a way, there is no danger to persons and other living beings.

- Cable reels rolled out completely. (cable fires)
- Do not use defective connectors or cables. (incl. plug-in strips)
- Cable routing must be properly installed.
- Never connect more than 2 plug strips together
- Protect electrical installations against wetness



7 Escape route at the stand

Escape routes from the tent or the sales booth must be free and accessible at all times.

The escape route must not be blocked or obstructed by exposed installation elements or other structures.



8 Feuerwehr

Zwischen den Ständen und Häusern muss einen 4 Meter Abstand für Feuerwehrdurchfahrt eingehalten werden. Die Feuerwehr wird eine Testfahrt machen. Stände müssen Ihre Markierung auf dem Boden einhalten. Sonst erfolgt einen Verweis.

9 Decorations at the stand

Do not use flammable decorative objects.

It is not allowed to enlarge the stand with rain- or sun roofs, stands etc..

GENERAL INFOS

All security elements mentioned above are checked by the market management. If there are any complaints, the market management reserves the right not to release the stand until the defects have been rectified.